



A P P R O V A L S ®

Certificate of Conformity/Approval

Certificate No.: SAA-203390-EA

Certificate Holder: Noark Electric (Shanghai) Co., Ltd.
No. 3857 Sixian Road, Songjiang District,
Shanghai
P.R. China

Regulatory Definition: Miniature Overcurrent Circuit-Breaker
Product Description: Moulded Case Circuit-breaker
Trade Name/s: NOARK
Model No.: Ex9BP
Rating/Marking/s: Ue: DC500V (2P in series), DC1000V (4P in series);
In: 10A, 13A, 16A, 20A, 25A, 32A, 40A, 50A, 63A;
Ics=Icu=6kA; Ui: 1000V;
Uimp: 4kV (2P in series), 6kV (4P in series)
Type C: li=12In±20%; Type K: li=17In±20%
Cat A.

Standard/s: AS/NZS IEC 60947.2:2015
AS/NZS IEC 60947.1:2015

Condition/s: Nil

Approval Marks: RCM (In accordance with AS/NZS 4417 and EESS requirements)
and
SAA-203390-EA (In accordance with NSW legislative requirements)

Initial Issue Date: 3 February 2021

Expiry Date: 3 February 2026

R. A. Hill


For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065, RECS accreditation under the Queensland Government legislative requirements and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and Certificate verification, go to:

www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 03-02-21 203390/1