

Certificate of Conformity

Global-Mark Pty. Ltd., certify the electrical equipment described hereunder complies with standards listed herein and notifies the certificate holder to affix the authorised Approval Mark on the product of the same type and the Regulatory Compliance Mark (RCM) mark provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled. In placing the Approval and RCM mark on the product, the Responsible Supplier makes a declaration of compliance with the certification standard(s) and confirms that the product is identical to the product certified herein. – This Certificate meets the requirements of a Recognised External Certification Scheme (EESS- RECS) and a Recognised External Approval Scheme (NSW-REAS).

CERTIFICATION AND CERTIFICATE HOLDER DETAILS

Company Name	NOARK Electrics (Shanghai) Co.,Ltd		
Address	3857 Sixian Road Songjiang District Shanghai - China		
Client ID	107480	Global-Mark File Number:	107480-003
Certificate Number & Approval Mark	GMA-509965-EA	Revision Number	00
Certification Standard(s)	AS/NZS IEC 60947.2:2015 Low-voltage switchgear and controlgear Part 2: Circuit-breakers		
Type of Certification	Electrical Safety Product	<i>Scheme</i>	Global-Mark Electrical Product Safety Certification Scheme

System 1 Approval

CERTIFICATE DATES

Certificate Issue Date	19/05/2021
Certificate Last Update Date	
Certification Expiry Date	19/05/2026

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager





global-mark®

Certificate of Conformity

CERTIFIED ELECTRICAL EQUIPMENT				
Declared Article	Product Description	Trade Name	Model Number	Rating
Miniature overcurrent circuitbreaker	DC Circuit Breaker	NOARK	Ex9BD 125 C16A	Ui:1200V, Uimp:8kV, In:16A; Ics=7.5Ka, Icu=10kA; Ue:DC300V(1P appearance); type C
Miniature overcurrent circuitbreaker	DC Circuit Breaker	NOARK	Ex9BD 125 C20A	Ui:1200V, Uimp:8kV, In:20A; Ics=7.5Ka, Icu=10kA; Ue:DC300V(1P appearance);, type C
Miniature overcurrent circuitbreaker	DC Circuit Breaker	NOARK	Ex9BD 125 C25A	Ui:1200V, Uimp:8kV, In:25A; Ics=7.5Ka, Icu=10kA; Ue:DC300V(1P appearance) ; type C
Miniature overcurrent circuitbreaker	DC Circuit Breaker	NOARK	Ex9BD 125 C32A	Ui:1200V, Uimp:8kV, In:32A; Ics=7.5Ka, Icu=10kA; Ue:DC300V(1P appearance) ; type C
Miniature overcurrent circuitbreaker	DC Circuit Breaker	NOARK	Ex9BD 125 C40A	Ui:1200V, Uimp:8kV, In:40A; Ics=7.5Ka, Icu=10kA; Ue:DC300V(1P appearance) ; type C
Miniature overcurrent circuitbreaker	DC Circuit Breaker	NOARK	Ex9BD 125 C50A	Ui:1200V, Uimp:8kV, In:50A; Ics=7.5Ka, Icu=10kA; Ue:DC300V(1P appearance) ; type C
Miniature overcurrent circuitbreaker	DC Circuit Breaker	NOARK	Ex9BD 125 C63A	Ui:1200V, Uimp:8kV, In:63A; Ics=7.5Ka, Icu=10kA; Ue:DC300V(1P appearance) ; type C
Miniature overcurrent circuitbreaker	DC Circuit Breaker	NOARK	Ex9BD 125 C80A	Ui:1200V, Uimp:8kV, In:80A; Ics=7.5Ka, Icu=10kA; Ue:DC300V(1P appearance) ; type C
Miniature overcurrent circuitbreaker	DC Circuit Breaker	NOARK	Ex9BD 125 C100A	Ui:1200V, Uimp:8kV, In:100A; Ics=7.5Ka, Icu=10kA; Ue:DC300V(1P appearance) ; type C
Miniature overcurrent circuitbreaker	DC Circuit Breaker	NOARK	Ex9BD 125 K16A	Ui:1200V, Uimp:8kV, In:16A; Ics=7.5Ka, Icu=10kA; Ue:DC300V(1P appearance) ; type K
Miniature overcurrent circuitbreaker	DC Circuit Breaker	NOARK	Ex9BD 125 K20A	Ui:1200V, Uimp:8kV, In:20A; Ics=7.5Ka, Icu=10kA; Ue:DC300V(1P appearance) ; type K
Miniature overcurrent circuitbreaker	DC Circuit Breaker	NOARK	Ex9BD 125 K25A	Ui:1200V, Uimp:8kV, In:25A; Ics=7.5Ka, Icu=10kA; Ue:DC300V(1P appearance) ; type K
Miniature overcurrent circuitbreaker	DC Circuit Breaker	NOARK	Ex9BD 125 K32A	Ui:1200V, Uimp:8kV, In:32A; Ics=7.5Ka, Icu=10kA; Ue:DC300V(1P appearance) ; type K
Miniature overcurrent circuitbreaker	DC Circuit Breaker	NOARK	Ex9BD 125 K40A	Ui:1200V, Uimp:8kV, In:40A; Ics=7.5Ka, Icu=10kA; Ue:DC300V(1P appearance) ; type K

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager

Global-Mark Pty Ltd, Copyright 2012 - 407, 32 Delhi Road, North Ryde NSW 2113, Australia



Global-Mark.com.au®



WWW.JAS-ANZ.ORG/REGISTER



global-mark®

Certificate of Conformity

Miniature overcurrent circuitbreaker	DC Circuit Breaker	NOARK	Ex9BD 125 K50A	Ui:1200V,Uimp:8kV,In:50A;Ics=7.5Ka, Icu=10kA; Ue:DC300V(1P appearance) ; type K
Miniature overcurrent circuitbreaker	DC Circuit Breaker	NOARK	Ex9BD 125 K63A	Ui:1200V,Uimp:8kV,In:63A;Ics=7.5Ka, Icu=10kA; Ue:DC300V(1P appearance) ; type K
Miniature overcurrent circuitbreaker	DC Circuit Breaker	NOARK	Ex9BD 125 K80A	Ui:1200V,Uimp:8kV,In:80A;Ics=7.5Ka, Icu=10kA; Ue:DC300V(1P appearance) ; type K
Miniature overcurrent circuitbreaker	DC Circuit Breaker	NOARK	Ex9BD 125 K100A	Ui:1200V,Uimp:8kV,In:100A;Ics=7.5Ka, Icu=10kA; Ue:DC300V(1P appearance) ; type K
Miniature overcurrent circuitbreaker	DC Circuit Breaker	NOARK	Ex9BD 125 C16A	Ui:1200V,Uimp:8kV,In:16A;Ics=7.5Ka, Icu=10kA; Ue:DC600V(2P appearance) ; type C
Miniature overcurrent circuitbreaker	DC Circuit Breaker	NOARK	Ex9BD 125 C20A	Ui:1200V,Uimp:8kV,In:20A;Ics=7.5Ka, Icu=10kA; Ue:DC600V(2P appearance) ; type C
Miniature overcurrent circuitbreaker	DC Circuit Breaker	NOARK	Ex9BD 125 C25A	Ui:1200V,Uimp:8kV,In:25A;Ics=7.5Ka, Icu=10kA; Ue:DC600V(2P appearance) ; type C
Miniature overcurrent circuitbreaker	DC Circuit Breaker	NOARK	Ex9BD 125 C32A	Ui:1200V,Uimp:8kV,In:32A;Ics=7.5Ka, Icu=10kA; Ue:DC600V(2P appearance) ; type C
Miniature overcurrent circuitbreaker	DC Circuit Breaker	NOARK	Ex9BD 125 C40A	Ui:1200V,Uimp:8kV,In:40A;Ics=7.5Ka, Icu=10kA; Ue:DC600V(2P appearance) ; type C
Miniature overcurrent circuitbreaker	DC Circuit Breaker	NOARK	Ex9BD 125 C50A	Ui:1200V,Uimp:8kV,In:50A;Ics=7.5Ka, Icu=10kA; Ue:DC600V(2P appearance) ; type C
Miniature overcurrent circuitbreaker	DC Circuit Breaker	NOARK	Ex9BD 125 C63A	Ui:1200V,Uimp:8kV,In:63A;Ics=7.5Ka, Icu=10kA; Ue:DC600V(2P appearance) ; type C
Miniature overcurrent circuitbreaker	DC Circuit Breaker	NOARK	Ex9BD 125 C80A	Ui:1200V,Uimp:8kV,In:80A;Ics=7.5Ka, Icu=10kA; Ue:DC600V(2P appearance) ; type C
Miniature overcurrent circuitbreaker	DC Circuit Breaker	NOARK	Ex9BD 125 C100A	Ui:1200V,Uimp:8kV,In:100A;Ics=7.5Ka, Icu=10kA; Ue:DC600V(2P appearance) ; type C
Miniature overcurrent circuitbreaker	DC Circuit Breaker	NOARK	Ex9BD 125 K16A	Ui:1200V,Uimp:8kV,In:16A;Ics=7.5Ka, Icu=10kA; Ue:DC600V(2P appearance) ; type K
Miniature overcurrent circuitbreaker	DC Circuit Breaker	NOARK	Ex9BD 125 K20A	Ui:1200V,Uimp:8kV,In:20A;Ics=7.5Ka, Icu=10kA; Ue:DC600V(2P appearance) ; type K

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager

Global-Mark Pty Ltd, Copyright 2012 - 407, 32 Delhi Road, North Ryde NSW 2113, Australia



Global-Mark.com.au®



WWW.JAS-ANZ.ORG/REGISTER



global-mark®

Certificate of Conformity

Miniature overcurrent circuitbreaker	DC Circuit Breaker	NOARK	Ex9BD 125 K25A	Ui:1200V,Uimp:8kV,In:25A;Ics=7.5Ka, Icu=10kA; Ue:DC600V(2P appearance) ; type K
Miniature overcurrent circuitbreaker	DC Circuit Breaker	NOARK	Ex9BD 125 K32A	Ui:1200V,Uimp:8kV,In:32A;Ics=7.5Ka, Icu=10kA; Ue:DC600V(2P appearance) ; type K
Miniature overcurrent circuitbreaker	DC Circuit Breaker	NOARK	Ex9BD 125 K40A	Ui:1200V,Uimp:8kV,In:40A;Ics=7.5Ka, Icu=10kA; Ue:DC600V(2P appearance) ; type K
Miniature overcurrent circuitbreaker	DC Circuit Breaker	NOARK	Ex9BD 125 K50A	Ui:1200V,Uimp:8kV,In:50A;Ics=7.5Ka, Icu=10kA; Ue:DC600V(2P appearance) ; type K
Miniature overcurrent circuitbreaker	DC Circuit Breaker	NOARK	Ex9BD 125 K63A	Ui:1200V,Uimp:8kV,In:63A;Ics=7.5Ka, Icu=10kA; Ue:DC600V(2P appearance) ; type K
Miniature overcurrent circuitbreaker	DC Circuit Breaker	NOARK	Ex9BD 125 K80A	Ui:1200V,Uimp:8kV,In:80A;Ics=7.5Ka, Icu=10kA; Ue:DC600V(2P appearance) ; type K
Miniature overcurrent circuitbreaker	DC Circuit Breaker	NOARK	Ex9BD 125 K100A	Ui:1200V,Uimp:8kV,In:100A;Ics=7.5Ka, Icu=10kA; Ue:DC600V(2P appearance) ; type K

RELEVANT TRADEMARK (S)

COMMENTS OR CONDITIONS ON THE CERTIFICATION
Nil

End of document

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager

Global-Mark Pty Ltd, Copyright 2012 - 407, 32 Delhi Road, North Ryde NSW 2113, Australia



Global-Mark.com.au®



WWW.JAS-ANZ.ORG/REGISTER