



Product Service

# Attestation of Conformity

No. N8A 075006 0060 Rev. 00

**Holder of Certificate:** **NOARK Electrics (Shanghai) Co., Ltd.**  
No.3857 Sixian Road, Songjiang District  
201614 Shanghai  
PEOPLE'S REPUBLIC OF CHINA

**Product:** **Switches for household and similar fixed el. installations**  
**Circuit-breakers for overcurrent protection for household and similar installations**

**Model(s):** **Ex9BH, Ex9BN, Ex9BS**

**Parameters:**

Rated operational voltage:	AC240/415V(1P), AC240V(1P+N), AC415V(2P, 3P, 3P+N, 4P)
Rated frequency:	50/60Hz
Rated current:	1A, 2A, 3A, 4A, 6A, 8A, 10A, 13A, 16A, 20A, 25A, 32A, 40A, 50A, 63A
Poles No.:	1P, 1P+N, 2P, 3P, 3P+N, 4P
Instantaneous tripping current:	B-, C- & D-type
Rated short-circuit capacity(Icn):	10kA (for Ex9BH) 6kA (for Ex9BN) 4.5kA (for Ex9BS)
Service short-circuit capacity(Ics):	7.5kA (for Ex9BH) 6kA (for Ex9BN) 4.5kA (for Ex9BS)
Energy limiting class:	3 (for Ex9BH)

**Tested according to:** EN 60898-1:2003/A13:2012

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance.

It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

**Test report no.:** 704101953201-00

**Date,** 2019-04-30

  
( Lutz Langguth )

Page 1 of 1

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.

ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFICAT