



A P P R O V A L S ®

Certificate of Conformity/Approval

Certificate No.: SAA101237EA

Certificate Holder: Noark Electric (Shanghai) Co., Ltd.
No. 3857 Sixian Road, Songjiang District,
Shanghai
P.R. China

Regulatory Definition: Miniature Overcurrent Circuit-Breaker
Product Description: Circuit Breaker
Trade Name/s: Noark
Model No.: EX9BN
Rating/Marking/s: Un= 240/415V~ (1P); or
230/400V~ (1P), 240V~ (1P+N); or
230V~ (1P+N), 415V~ (2P, 3P, 3P+N, 4P); or
400V~ (2P, 3P, 3P+N, 4P)
In= 1, 2, 3, 4, 6, 8, 10, 13, 16, 20, 25, 32, 40, 50, 63A
B, C or D type
Ics= Icn= 6000A Uimp=4kV

Standard/s: AS/NZS 60898.1:2004
Condition/s: Nil

Approval Marks: RCM (In accordance with AS/NZS 4417 and EESS requirements)
and
SAA101237EA (In accordance with NSW legislative requirements)


Initial Issue Date: 5 November 2010
Expiry Date: 5 November 2025

R. A. Hill

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065, RECS accreditation under the Queensland Government legislative requirements and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein. For SAA Contact Details and Certificate verification, go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 15-10-20 101237/1c
Rating corrected