

## Test Verification of Conformity


On the basis of the referenced test report(s), the sample(s) of the below product has been found to comply with the relevant harmonized standard(s) to the directive(s) listed on this verification at the time the tests were carried out.

The manufacturer may indicate compliance to only the said directives by signing a DoC himself and may affix the CE marking to products identical to the tested sample(s) if the product complies with all CE marking directives that has the product in their scope. In addition, the manufacturer shall file and keep the documentation according to the rules of the applicable directive(s) and shall consider changes of the standards as they may occur. Additional requirements, additional directives and local laws may be applicable.

<b>Applicant Name &amp; Address</b>	: NOARK Electrics (Shanghai) Co., Ltd. Block V-7A-1, Songjiang Industrial Zone Shanghai China
<b>Manufacturer Name &amp; Address</b>	: NOARK Electrics (Shanghai) Co., Ltd. Block V-7A-1, Songjiang Industrial Zone Shanghai China
<b>Product(s) Tested</b>	: Surge protective device
<b>Ratings and principal characteristics</b>	: IP 20, type 2, See annex for details
<b>Model(s)</b>	: See annex
<b>Brand name</b>	: NOARK
<b>Relevant Standard(s) / Specification(s) / Directive(s)</b>	: EN 61643-11:2002 + A11:2007 the Low Voltage Directive 2006/95/EC
<b>Verification Issuing Office Name &amp; Address</b>	: Intertek Testing Services Shanghai Building No.86, 1198 Qinzhou Road (North), Shanghai 200233, China
<b>Verification Number</b>	: SH09090972-V2
<b>Report Number(s)</b>	: SH09090972-002

**NOTE 1: This verification is part of the full test report(s) and should be read in conjunction with it.**

This Verification is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to copy or distribute this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results referenced from this Verification are relevant only to the sample tested. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

**Leo Shi**  
**Manager**  
**June 12, 2010**

# Annex to Test Verification of Conformity

This is an Annex to Test Verification of Conformity with SH09090972-V2. The issuing office is Intertek Testing Services Shanghai Building No.86, 1198 Qinzhou Road (North), Shanghai 200233, China

## Rating and principal characteristics:

Series	Uc(V)~		Imax(kA)		In(kA)		Up(kV)	
	L-N/N-PE	L(N)-PE	L-N/N-PE	L(N)-PE	L-N/N-PE	L(N)-PE	L-N/N-PE	L(N)-PE
Ex9U2 30	275/275	275	30	30	15/15	15	1.3/1.3	1.3/1.3
	320/320	320					1.5/1.5	1.5/1.5
	385/385	385					1.8/1.8	1.8/1.8
	440/440	440					2.2/2.2	2.2/2.2
Ex9U2 40	275/275	275	40	40	20/20	20	1.3/1.3	1.3/1.3
	320/320	320					1.5/1.5	1.5/1.5
	385/385	385					1.8/1.8	1.8/1.8
	440/440	440					2.2/2.2	2.2/2.2
Ex9U2 65	275/275	275	65	65	30/30	30	1.5/1.5	1.5/1.5
	320/320	320					1.8/1.8	1.8/1.8
	385/385	385					2.0/2.0	2.0/2.0
	440/440	440					2.5/2.5	2.5/2.5
Ex9U2 120	275/275	275	120	120	65/65	65	2.0/2.0	2.0/2.0
	320/320	320					2.5/2.5	2.5/2.5
	385/385	385					2.8/2.8	2.8/2.8
	440/440	440					3.0/3.0	3.0/3.0


Each rating have 1P, 2P, 3P, and 4P models

### Model list:

Ex9U2 30(R) 1P 275, Ex9U2 30(R) 1P 320, Ex9U2 30(R) 1P 385, Ex9U2 30(R) 1P 440  
 Ex9U2 30(R) 2P 275, Ex9U2 30(R) 2P 320, Ex9U2 30(R) 2P 385, Ex9U2 30(R) 2P 440  
 Ex9U2 30(R) 3P 275, Ex9U2 30(R) 3P 320, Ex9U2 30(R) 3P 385, Ex9U2 30(R) 3P 440  
 Ex9U2 30(R) 4P 275, Ex9U2 30(R) 4P 320, Ex9U2 30(R) 4P 385, Ex9U2 30(R) 4P 440  
 Ex9U2 40(R) 1P 275, Ex9U2 40(R) 1P 320, Ex9U2 40(R) 1P 385, Ex9U2 40(R) 1P 440  
 Ex9U2 40(R) 2P 275, Ex9U2 40(R) 2P 320, Ex9U2 40(R) 2P 385, Ex9U2 40(R) 2P 440  
 Ex9U2 40(R) 3P 275, Ex9U2 40(R) 3P 320, Ex9U2 40(R) 3P 385, Ex9U2 40(R) 3P 440  
 Ex9U2 40(R) 4P 275, Ex9U2 40(R) 4P 320, Ex9U2 40(R) 4P 385, Ex9U2 40(R) 4P 440  
 Ex9U2 65(R) 1P 275, Ex9U2 65(R) 1P 320, Ex9U2 65(R) 1P 385, Ex9U2 65(R) 1P 440  
 Ex9U2 65(R) 2P 275, Ex9U2 65(R) 2P 320, Ex9U2 65(R) 2P 385, Ex9U2 65(R) 2P 440  
 Ex9U2 65(R) 3P 275, Ex9U2 65(R) 3P 320, Ex9U2 65(R) 3P 385, Ex9U2 65(R) 3P 440  
 Ex9U2 65(R) 4P 275, Ex9U2 65(R) 4P 320, Ex9U2 65(R) 4P 385, Ex9U2 65(R) 4P 440  
 Ex9U2 120(R) 1P 275, Ex9U2 120(R) 1P 320, Ex9U2 120(R) 1P 385, Ex9U2 120(R) 1P 440  
 Ex9U2 120(R) 2P 275, Ex9U2 120(R) 2P 320, Ex9U2 120(R) 2P 385, Ex9U2 120(R) 2P 440  
 Ex9U2 120(R) 3P 275, Ex9U2 120(R) 3P 320, Ex9U2 120(R) 3P 385, Ex9U2 120(R) 3P 440  
 Ex9U2 120(R) 4P 275, Ex9U2 120(R) 4P 320, Ex9U2 120(R) 4P 385, Ex9U2 120(R) 4P 440 (totally 64 models)

**NOTE: This annex is part of the Test Verification of Conformity and should be read in conjunction with it.**

This Verification is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to copy or distribute this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results referenced from this Verification are relevant only to the sample tested. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.



**Leo Shi**  
**Manager**  
**June 12, 2010**