## B type RCCBs Ex9LB63




- Residual Current Circuit Breakers according to IEC/EN 61008-1 and IEC/EN 62423
- Cond. rated short circuit strength I<sub>nc</sub> 10 kA
- B type
- 2 and 4-pole versions
- Rated residual current 30, 100 and 300 mA
- Rated current up to 63 A
- Rated operational voltage 230/400 V AC
- Indication of electrical tripping
- Suitable for applications from -25 to +40 °C

Residual current circuit breakers B type Ex9LB63 are suitable for domestic as well as industrial applications, where are used frequency inveters, PV plant, EV chargers and similar elements. B type provides a sensitivity to residual AC, pulsating and smooth DC current, together with high frequencies up to 1 kHz.

They are based on electronic technology, which brings advantages of more accurate measuring of residual current and, as a consequence, reduction of unwanted tripping. These devices also do not suffer with magnetization of the tripping unit. Thus, there is no mandatory testing period, but they must be tested regularly. On this testing period local law or regulations may apply. Recommend is to test it every 6 months in fair environment and every month in heavy condition.

#### Type Key



#### **Certification marks**





# B type RCCBs Ex9LB63

## B type, 2-pole

- B type sensitivity to residual AC, pulsating and smooth DC current, high frequency up to 1 kHz
- · Without time delay
- Surge current-proof 3000 A
- 30 mA version suitable for protection of people in case of direct and indirect contact with live parts and exposed conductive parts during a fault, respectively



Rated current	Rated residual current	Poles	Article No.	Туре	Packing
25 A	30 mA	2	110212	Ex9LB63 1P+N 25A 30mA	1/72
40 A	30 mA	2	110213	Ex9LB63 1P+N 40A 30mA	1/72
63 A	30 mA	2	110214	Ex9LB63 1P+N 63A 30mA	1/72
25 A	100 mA	2	110215	Ex9LB63 1P+N 25A 100mA	1/72
40 A	100 mA	2	110216	Ex9LB63 1P+N 40A 100mA	1/72
63 A	100 mA	2	110217	Ex9LB63 1P+N 63A 100mA	1/72
25 A	300 mA	2	110218	Ex9LB63 1P+N 25A 300mA	1/72
40 A	300 mA	2	110219	Ex9LB63 1P+N 40A 300mA	1/72
63 A	300 mA	2	110220	Ex9LB63 1P+N 63A 300mA	1/72

### B type, 4-pole



Rated current	Rated residual current	Poles	Article No.	Туре	Packing
25 A	30 mA	4	110221	Ex9LB63 3P+N 25A 30mA	1/45
40 A	30 mA	4	110222	Ex9LB63 3P+N 40A 30mA	1/45
63 A	30 mA	4	110223	Ex9LB63 3P+N 63A 30mA	1/45
25 A	100 mA	4	110224	Ex9LB63 3P+N 25A 100mA	1/45
40 A	100 mA	4	110225	Ex9LB63 3P+N 40A 100mA	1/45
63 A	100 mA	4	110226	Ex9LB63 3P+N 63A 100mA	1/45
25 A	300 mA	4	110227	Ex9LB63 3P+N 25A 300mA	1/45
40 A	300 mA	4	110228	Ex9LB63 3P+N 40A 300mA	1/45
63 A	300 mA	4	110229	Ex9LB63 3P+N 63A 300mA	1/45

# **Technical Data Ex9LB63**

### Residual Current Circuit Breakers type B, 10 kA

### General parameters

Electronic evaluation principle - more accurate measuring of residual current

Suitable for household as well as industrial applications

B type - sensitivity to residual AC, pulsating and smooth DC current, high frequency up to 1 kHz

Device must be tested regularly. Local laws or regulations can be applied. Recommend is a testing period of 6 months in normal condition, 1 month in heavy conditions

In case all wires are not connected at 4-pole RCCB, it is necessary to ensure that circuit of the test button T is supplied with appropriate voltage (by means of mutual connection of respective terminals of the RCCB, see wiring diagram)

Internal SPD protection to improve service life and make it applicable to multiple installation environments

Parallel construction of the type A/AC and type B internal parts. If required voltage is not available for type B internal electronics, the protection type A and AC will be still provided


Indication of electrical tripping

Tested according to	IEC/EN 61008-1, IEC/EN 62423		
Rated operational voltage U <sub>e</sub>	230/240 V AC (2-pole) 400/415 V AC (4-pole)		
Min. voltage for RCD function	voltage independent for type A and AC voltage dependent for type B (from 85 V AC)		
Voltage range of the test button T	150 — 254 V AC (2-pole) 150 — 440 V AC (4-pole)		
Rated frequency f	50 Hz		
Conditional short circuit strength I <sub>nc</sub>	10 kA		
Rated current I <sub>n</sub>	25, 40, 63 A		
Rated residual current I <sub>Δn</sub>	30, 100, 300 mA		
Sensitivity to residual current	B type - residual AC, pulsating and smooth DC current, high frequency (1 kHz)		
Rated impulse withstand voltage U <sub>imp</sub>	4 kV		
Rated insulation voltage U <sub>i</sub>	500 V		
Surge current proof	3000 A		
Mechanical service life	10 000 operation cycles		
Electrical service life	2 000 operation cycles		
Back-up fuse for overload			
I <sub>n</sub> = 25 A	max. 25 A gG		
I <sub>n</sub> = 40 A	max. 32 A gG		
I <sub>n</sub> = 63 A	max. 50 A gG		
Back-up fuse for short circuit			
I <sub>n</sub> = 25 A	max. 63 A gG		
I <sub>n</sub> = 40 A	max. 63 A gG		
I <sub>n</sub> = 63 A	max. 63 A gG		
Rated making capacity $I_m$ (rated residual making capacity $I_{\rm Am}$ )			
I <sub>n</sub> = 25 A	500 A		
I <sub>n</sub> = 40 A	500 A		
I <sub>n</sub> = 63 A	630 A		
Line voltage connection	arbitrary above or below		



# **Technical Data Ex9LB63**

### Residual Current Circuit Breakers type B, 10 kA



Power loss			
I <sub>n</sub>	$\mathbf{I}_{\Delta}$	2P	4P
25 A	30 mA	6.6 W	8.6 W
	100 mA	4.3 W	8.6 W
	300 mA	4.3 W	8.6 W
40 A	30 mA	6.9 W	13.7 W
	100 mA	10.5 W	13.7 W
	300 mA	10.5 W	13.7 W
63 A	30 mA	16.5 W	21.6 W
	100 mA	10.9 W	21.6 W
	300 mA	10.9 W	21.6 W

