



A P P R O V A L S ®

Certificate of Conformity/Approval

Certificate No.: SAA-220190-EA

Certificate Holder: Noark Electric (Shanghai) Co., Ltd.
No. 3857 Sixian Road, Songjiang District,
Shanghai
P.R. China

Regulatory Definition: Miniature Overcurrent Circuit-Breaker

Product Description: Circuit-Breakers (MCCB)

Standard/s: AS/NZS IEC 60947.2:2015
AS/NZS IEC 60947.1:2015

Condition/s: Nil

Approval Marks: RCM (In accordance with AS/NZS 4417 and EESS requirements)
and
SAA-220190-EA (In accordance with NSW legislative requirements)

Initial Issue Date: 15 February 2022

Expiry Date: 15 February 2027

R. A. Hill

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065, RECS accreditation under the Queensland Government legislative requirements and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and Certificate verification, go to:

www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 15-02-22 220190
Page 1 of 3



A P P R O V A L S ®

Certificate of Conformity/Approval

Model	Trade Name	Rating/Marking
B1E2P125	NOARK	Ue: DC80V/125V/220V/250V(2P) In: 125A Icu: 20kA/20kA/10kA/10kA(2P) Ics: 15kA/15kA/7,5kA/7,5kA(2P) Uimp: 4kV, Ui= 500V Cat A.
B1E2P63	NOARK	Ue: DC80V/125V/220V/250V(2P) In: 63A Icu: 20kA/20kA/10kA/10kA(2P) Ics: 15kA/15kA/7,5kA/7,5kA(2P) Uimp: 4kV, Ui= 500V Cat A.
B1E2P70	NOARK	Ue: DC80V/125V/220V/250V(2P) In: 70A Icu: 20kA/20kA/10kA/10kA(2P) Ics: 15kA/15kA/7,5kA/7,5kA(2P) Uimp: 4kV, Ui= 500V Cat A.
B1E2P80	NOARK	Ue: DC80V/125V/220V/250V(2P) In: 80A Icu: 20kA/20kA/10kA/10kA(2P) Ics: 15kA/15kA/7,5kA/7,5kA(2P) Uimp: 4kV, Ui= 500V Cat A.
B1E2P90	NOARK	Ue: DC80V/125V/220V/250V(2P) In: 90A Icu: 20kA/20kA/10kA/10kA(2P) Ics: 15kA/15kA/7,5kA/7,5kA(2P) Uimp: 4kV, Ui= 500V Cat A.

R. A. Hill

For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065, RECS accreditation under the Queensland Government legislative requirements and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and Certificate verification, go to:

www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 15-02-22 220190
Page 2 of 3



A P P R O V A L S ®

Certificate of Conformity/Approval

Model	Trade Name	Rating/Marking
B1E2P100	NOARK	Ue: DC80V/125V/220V/250V(2P) In: 100A Icu: 20kA/20kA/10kA/10kA(2P) Ics: 15kA/15kA/7,5kA/7,5kA(2P) Uimp: 4kV, Ui= 500V Cat A.

R. A. Hill


For and on Behalf of
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065, RECS accreditation under the Queensland Government legislative requirements and REAS accreditation under the NSW Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and Certificate verification, go to:

www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 15-02-22 220190
Page 3 of 3